
MINIMUM STREET TREE CLEARANCES

- 1. STREET TREES SHALL BE LOCATED 8 FEET (MIN) FROM SANITARY SEWER, GAS, AND STORMWATER LINES.
- 2. STREET TREES SHALL BE LOCATED 5 FEET (MIN) FROM WATER, TELEPHONE AND ELECTRICAL LINES.
- 3. STREET TREES SHALL BE LOCATED 5 FEET (MIN) FROM FIRE HYDRANTS.
- 4. STREET TREES SHALL BE LOCATED 15 FEET (MIN) FROM STREET LIGHTS.
- 5. STREET TREES SHALL BE LOCATED 8 FEET (MIN) FROM DRIVEWAYS AND 4 FEET (MIN) AT CUL-DE-SAC.
- 6. STREET TREES SHALL BE GENERALLY 35 FEET ON CENTER.
- 7. STREET TREES SHALL BE LOCATED 15 FEET (MIN) FROM CURB RETURNS.
- 8. MINIMUM ONE TREE PER LOT REQUIRED, AND TWO PER CORNER LOT.
- 9. IF LOT WIDTH EXCEEDS 60 FEET AT THE STREET, ONE TREE IS REQUIRED EVERY 35 FEET OF STREET, EXCLUDING LENGTH OF CURB RETURN.



NOTE: CURRENT STANDARD DETAIL AT CITY ENGINEERING DIVISION SHALL PREVAIL

			CIT	Y OF	FREM	ONT	DATE APPROVED BY CITY COUNCI 04/11/0	=	
				STANDARD DETAILS			RESOLUTION NO. 2006-31		
			CITY STANDARD						
APPR	REVISED	DATE	STREET TREE CLEARANCES Num					Hughen	
	REVISIONS	5					CITY ENGINEER		
FILE NO.		SCALE		DRAWN	CHECKED	DATE	DWG NO.		
LSD-05.DWG		1" = 20'-0"		PM/MM	RER	OCT. 2005	LSD-5	1 of 1	